



# GLOUCESTER TOWNSHIP FIRE DISTRICT 6

## BUREAU OF FIRE PREVENTION

1946 Williamstown Road  
Erial, N.J. 08081  
856-435-0700 / FAX 856-435-4274  
Inspections@GTFD6.com

### SMOKE DETECTOR, CARBON MONOXIDE DETECTOR AND FIRE EXTINGUISHER CERTIFICATION APPLICATION

**Owner Information:**

Owner Name: \_\_\_\_\_

Property Address: \_\_\_\_\_  
\_\_\_\_\_

Phone: \_\_\_\_\_

E-Mail: \_\_\_\_\_

Block: \_\_\_\_\_ Lot: \_\_\_\_\_

Property Status:  Occupied  Vacant

**Realtor Information:**

Realtor Name: \_\_\_\_\_

Realtor Address: \_\_\_\_\_  
\_\_\_\_\_

Realtor: \_\_\_\_\_

Phone: \_\_\_\_\_

E-Mail: \_\_\_\_\_

Settlement Date: \_\_\_\_\_

**Inspection Checklist**

- Numbers are numerical characters, contrasting color from the house, at least 4" high, permanently affixed to the house & visible from the street. *Light post or mailbox numbers are NOT acceptable.*

**Smoke Alarms**

- Smoke alarm located on **every level** of dwelling. **Smoke alarms must be less than 10 years old and OPERATIONAL.**
- Basement level alarm is located at bottom of stairwell, at ceiling level (not between joists).
- Bedroom hallway alarms **MUST** be within 10 feet of **ALL** bedroom doors.
- \*Electric smoke alarms (hardwired) **CANNOT** be replaced with battery operated alarms.
- Do **NOT** install smoke alarms in kitchens, bathrooms, near forced air ducts or furnaces, in the "dead air" space where the ceiling meets the wall, close to ceiling fans, in crawl spaces or attics.

**Carbon Monoxide Alarms**

- Located in the hallway, within 10 feet of **ALL** bedroom doors.
- Installed per manufacturer's instructions.
- Carbon monoxide alarm(s) are less than 7 years old and are operational.
- Do **NOT** place alarms in electrical outlets that can be turned off by a switch or that are located against floor molding. Plug-in, battery powered and hardwired CO alarms are acceptable.

**Fire Extinguisher**

- **ABC** type, rated for residential use.
- Shall be **2A:10B:C**, and weight no more than 10 pounds.
- Must be dated or tagged for current year.
- **MOUNTED** within 10 feet of the kitchen.

**Fees**

Inspections requested 10 or more days prior to settlement.	<b>\$35.00</b>
Inspections requested 4-9 days prior to settlement.	<b>\$70.00</b>
Inspections requested less than 4 days prior to settlement.	<b>\$125.00</b>

Please include cash/check made payable to: **GTFD6**

**OFFICE USE ONLY**

Date Received: \_\_\_\_\_

Payment Method: \_\_\_\_\_

Receipt #: \_\_\_\_\_

Recorded by: \_\_\_\_\_

Scheduled for: \_\_\_\_\_

Time: \_\_\_\_\_